WEST VIEW WATER AUTHORITY
210 Perry Highway
Pittsburgh, Pennsylvania 15229
Administrative (412) 931-3292
Customer Service (412) 931-3500
Customer Information www.westviewwater.org

Water Analysis

3rd Quarter 2026

Calcium[1]	72	ppm Ca as $CaCO_3$
Total Magnesium[3]	8.505	ppm Mg as $CaCO_3$
P. Alkalinity[1]	6	ppm P. Alk. as $CaCO_3$
M. Alkalinity[1]	64	ppm Total Alk. as $CaCO_3$
Nitrogen[2]	0.711	ppm as Nitrate
Nitrogen[2]	<0.100	ppm as Nitrite
Total Iron[1]	0.00	ppm as Fe
Total Manganese[1]	0.007	ppm as Mn
Aluminum[1]	0.000	Ppm as Al
Free Chlorine[1]	1.98	ppm as Cl_2
Total Chlorine[1]	2.14	ppm as Cl_2
Ca Hardness[1]	72	ppm as $CaCO_3$
Total Hardness[1]	107	ppm as $CaCO_3$
Fluoride[1]	0.74	ppm as F
Lead[3]	<0.0025	ppm as Pb
Specific Conductance[1]	387	Micromhos/cm
pH[1]	8.65	S.U.
Turbidity[1]	0.046	NTU
Total Dissolved Solids[1]	186	ppm
Average Trihalomethanes (THM) for the first quarter of 2025	0.028	ppm
Average Haloacetic Acids (HAA) for the first quarter of 2025	0.010	ppm
Total Coliforms[1]	< 1	per 100 mL

[1] = Quarterly Average
[2] = Sampled Annually
[3] = As Needed/Calculated

7/22/2026